N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16048-7-1725
State Number
6817

EQUIPMENT INSPECTED

State Number: **6817**
Capacity: 1500
Landings: 2
Volts: 208

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 12/22/1970
Complied: 12/22/1970

Floor to Floor: 1 to 2
Speed: 100
Rope Size: 0
Entrances: 1

OWNER
ALEXANDER COUNTY SCHOOLS
700 LILEDOUN ROAD
TAYLORSVILLE, NC, 28681

OCCUPANT
ALEXANDER CENTRAL HIGH SCHOOL
241 SCHOOL AVENUE
TAYLORSVILLE, NC, 28681

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
02/17/2016	Routine	Re-issued	7 - Hoffman	ALEXANDER

2

VIOLATIONS

NONE

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: ALEAXNDER CO SCHOOLS828-632-7063 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ALEXANDER COUNTY SCHOOLS
700 LILEDOUN ROAD
TAYLORSVILLE, NC, 28681