



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16056-38-167
State Number
10679

EQUIPMENT INSPECTED

State Number: 10679	Type of Unit: Passenger	Floor to Floor: 1 to 6
Capacity: 2500	Manuf: ASHEVILLE	Speed: 150
Landings: 6	Installed: 03/01/1984	Rope Size:
Volts: 208	Complied: 03/01/1984	Entrances: 1
OWNER	OCCUPANT	
AMBICA LLC	HOLIDAY INN ASHEVILLE	
PO BOX 2470	435 SMOKEY PARK HWY	
CANDLER, NC, 28705	ASHEVILLE, NC, 28806	

INSPECTION INFORMATION

Inspection Date 02/25/2016	Type Inspection Alteration	Certificate Status Issued	Inspector 38 - Raborn	County BUNCOMBE	11 A
-------------------------------	-------------------------------	------------------------------	--------------------------	--------------------	------

VIOLATIONS

NOTE UNIT IN COMPLIANCE WITH A17.1
NOTE WORK PRESS= 260 RELIEF PRESS= 360

Elevator Name: #1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Randy Barlet 828.274.3633

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AMBICA LLC
PO BOX 2470
CANDLER, NC, 28705