



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16057-36-2916
State Number
23257

EQUIPMENT INSPECTED

State Number: 23257	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 55
Landings: 2	Installed: 08/18/2005	Rope Size:
Volts: 208	Complied: 08/24/2005	Entrances: 1
OWNER	OCCUPANT	
ELON UNIVERSITY	JOHNSTON HALL (SOUTH CAMPUS)	
801 HAGGARD AVE	123 S ANTIOCH AVE	
ELON, NC, 27244	ELON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 02/26/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

Elevator Name: Johnston Hall

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Bob Willis 336.278.2000

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSITY
801 HAGGARD AVE
ELON, NC, 27244