



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16057-63-0121
State Number
19496

EQUIPMENT INSPECTED

State Number: 19496	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 12/06/2000	Rope Size:
Volts: 208	Complied: 12/06/2000	Entrances: 1
OWNER	OCCUPANT	
MILT PETTY	ALAMANCE IND. PARK	
PO BOX 850	1225 HUFFMAN MILL RD	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 02/26/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 63 - Yarbrough	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-----------------------------	--------------------

1

VIOLATIONS

8.6.1.6.5 Provide a class ABC fire extinguisher in machinery space. Current extinguisher is out of date.

Items must be corrected by: 03/27/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Milt Petty

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

MILT PETTY
PO BOX 850
BURLINGTON, NC, 27215