



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16057-63-4679
State Number
23316

EQUIPMENT INSPECTED

State Number: 23316	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 06/23/2005	Rope Size: .
Volts: 208	Complied: 06/23/2005	Entrances: 1
OWNER	OCCUPANT	
AKHLAGHI OFFICE BLDG	AKHLAGHI OFFICE BLDG	
2961 CROUSE LN	2961 CROUSE LN	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 02/26/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 63 - Yarbrough	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-----------------------------	--------------------

1

VIOLATIONS

8.6.4.13.1[[]]	Properly maintain door restrictors, where required.
8.6.1.6.5	Provide a class ABC fire extinguisher in machinery space.Current extinguisher is out of date.

Items must be corrected by: 03/27/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Dr. Jadali,336-586-9799

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AKHLAGHI OFFICE BLDG
2961 CROUSE LN
BURLINGTON, NC, 27215