



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**16060-17-5589**  
State Number  
**25777**

EQUIPMENT INSPECTED

State Number: <b>25777</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 5000	Manuf: TKE	Speed: 125
Landings: 3	Installed: 03/28/2008	Rope Size:
Volts: 480	Complied:	Entrances: 2

OWNER

10 BROOK STREET LLC  
10 BROOK ST STE 205  
ASHEVILLE, NC, 28803

OCCUPANT

10 BROOK STREET  
10 BROOK STREET  
ASHEVILLE, NC, 28803

INSPECTION INFORMATION

Inspection Date 02/29/2016	Type Inspection Removed	Certificate Status Not Issued	Inspector 17 - White	County BUNCOMBE	11 A
-------------------------------	----------------------------	----------------------------------	-------------------------	--------------------	------

VIOLATIONS

note unit is down for repairs.

Items must be corrected by: 02/29/2016

Elevator Name: B

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Brian Keefer 828-398-6862

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

10 BROOK STREET LLC  
10 BROOK ST STE 205  
ASHEVILLE, NC, 28803