N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16067-48-301
State Number
29982

EQUIPMENT INSPECTED

State Number: **29982**
Capacity: 3500
Landings: 4
Volts: 208

Type of Unit: Passenger
Manuf: SCHINDLER
Installed: 06/02/2015
Complied:

Floor to Floor: 1 to 4
Speed: 125
Rope Size:
Entrances: 1

OWNER
CAM
PO BOX 8126
OCEAN ISLE, NC, 28469

OCCUPANT
DOLPHIN SHORES AT HOLDEN BEACH
2252 DOLPHIN SHORES BLVD SW
SUPPLY, NC, 28462

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
03/07/2016	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

8.6.4.7.4	Remove the oil from the pit floor.
N/A	KNOCK BETWEEN 3RD AND 4TH FL.

Items must be corrected by: 04/06/2016

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
CAM
PO BOX 8126
OCEAN ISLE, NC, 28469