



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16068-36-1267
State Number
H481

EQUIPMENT INSPECTED

State Number: H481	Type of Unit: Hand Lift	Floor to Floor: LL to UL
Capacity: 750	Manuf: NATL W-O-V	Speed: 9
Landings: 2	Installed: 07/20/1993	Rope Size:
Volts: 110	Complied: 07/20/1993	Entrances: 2
OWNER	OCCUPANT	
LAB CORP	LAB CORP (FEDERAL BUILDING)	
348 S MAIN ST	403 S SPRING ST	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 03/08/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: LORIE FLINCHUM 336-436-7777

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LAB CORP
348 S MAIN ST
BURLINGTON, NC, 27215