



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**16068-48-1824**  
State Number  
**23469**

### EQUIPMENT INSPECTED

State Number: <b>23469</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 55
Landings: 3	Installed: 09/08/2005	Rope Size:
Volts: 240	Complied: 09/09/2005	Entrances: 1
OWNER THE WOODLANDS @ CROW CREEK 10255 BEACH DR SW CALABASH, NC, 28467		OCCUPANT CROW CREEK BLDG #6 260 WOODLANDS WAY CALABASH, NC, 28467

### INSPECTION INFORMATION

Inspection Date 03/08/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

### VIOLATIONS

8.6.4.7.1	Clean the elevator pit.
8.6.4.8.1	Clean the machine room (machinery space) of all debris.

Items must be corrected by: 04/07/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

THE WOODLANDS @ CROW CREEK  
10255 BEACH DR SW  
CALABASH, NC, 28467