



INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**16068-48-3812**  
State Number  
**22317**

EQUIPMENT INSPECTED

State Number: <b>22317</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 2100
Landings: 3	Installed: 10/20/2004	Rope Size:
Volts: 240	Complied: 11/04/2004	Entrances: 1
OWNER THE WOODLANDS @ CROW CREEK 10255 BEACH DR SW CALABASH, NC, 28467	OCCUPANT CROW CREEK CONDOS #4 280 WOODLANDS WAY, SW CALABASH, NC, 28467	

INSPECTION INFORMATION

Inspection Date 03/08/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.7.1	Clean the elevator pit.
2.27.1.1.2	Put the in car emergency telephone in proper working order.
8.6.8.9	Signs. Caution signs shall be provided. Damaged or missing signs shall be replaced. [2ND FL.]

Items must be corrected by: 04/07/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:  
THE WOODLANDS @ CROW CREEK  
10255 BEACH DR SW  
CALABASH, NC, 28467