



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16070-48-0362
State Number
24648

EQUIPMENT INSPECTED

State Number: 24648	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 55
Landings: 3	Installed: 02/01/2007	Rope Size: 0
Volts: 230	Complied:	Entrances: 1
OWNER	OCCUPANT	
CROW CREEK BLDG #11	CROW CREEK - BLDG #11	
395 SOUTH CROW CREEK DRIVE	395 SOUTH CROW CREEK DRIVE	
CALABASH, NC, 28467	CALABASH, NC, 28467	

INSPECTION INFORMATION

Inspection Date 03/10/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CROW CREEK BLDG #11
395 SOUTH CROW CREEK DRIVE
CALABASH, NC, 28467