



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16075-16-3018
State Number
9865

EQUIPMENT INSPECTED

State Number: 9865	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: SOUTHERN	Speed: 125
Landings: 4	Installed: 08/17/1981	Rope Size: 0
Volts: 208	Complied: 05/12/2003	Entrances: 1
OWNER	OCCUPANT	
WASHINGTON HOUSING AUTHORITY	EAST HAVEN	
PO BOX 1046	407 E. THIRD STREET	
WASHINGTON, NC, 27889	WASHINGTON, NC, 27889	

INSPECTION INFORMATION

Inspection Date 03/15/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

2.14.7.1.3 Put the in car emergency light in working order.

Items must be corrected by: 04/14/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Kimberly Stanley / Building Manager

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WASHINGTON HOUSING AUTHORITY
PO BOX 1046
WASHINGTON, NC, 27889