



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16075-36-366
State Number
24720

EQUIPMENT INSPECTED

State Number: 24720	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2500	Manuf: TKE	Speed: 350
Landings: 4	Installed: 09/23/2008	Rope Size: 3/4
Volts: 480	Complied: 09/23/2008	Entrances: 1
OWNER	OCCUPANT	
LABCORP	LABCORP HEADQUARTERS	
531 S SPRING STREET	531 S SPRING STREET	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 03/15/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

5.1.21.1 Put the in car alarm bell in working order.

Items must be corrected by: 04/14/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: LORIE FLINCHUM 33-436-7777

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LABCORP
531 S SPRING STREET
BURLINGTON, NC, 27215