



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

### INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**16075-48-0964**  
State Number  
**23191**

### EQUIPMENT INSPECTED

State Number: <b>23191</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: CANTON	Speed: 100
Landings: 3	Installed: 08/22/2005	Rope Size:
Volts: 240	Complied: 08/22/2005	Entrances: 1
OWNER	OCCUPANT	
LAWRENCE COASTAL REAL ESTATE	SOUTHPORT CONDOS BLDG #4	
5003 O'QUINN BLVD.	612 WEST BROWN ST	
SOUTHPORT, NC, 28461	SOUTHPORT, NC, 28461	

### INSPECTION INFORMATION

Inspection Date 03/15/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

### VIOLATIONS

8.6.4.13.1[f] Properly maintain hangers, tracks, door rollers, up-thrusts, and door safety retainers, where required. [CAR GATE SQUEAK]  
N/A LONG DWELL TIME IN UP DIR.]

Items must be corrected by: 04/14/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

LAWRENCE COASTAL REAL ESTATE  
5003 O'QUINN BLVD.  
SOUTHPORT, NC, 28461