



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16077-48-1192
State Number
26742

EQUIPMENT INSPECTED

State Number: 26742	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 08/17/2009	Rope Size:
Volts: 208	Complied: 08/17/2009	Entrances: 1

OWNER

MT PISGAH BAPTIST CHURCH
494 MT PISGAH ROAD SW
SUPPLY, NC, 28462

OCCUPANT

MT PISGAH BAPTIST CHURCH
494 MT PISGAH ROAD SW
SUPPLY, NC, 28462

INSPECTION INFORMATION

Inspection Date 03/17/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

MT PISGAH BAPTIST CHURCH
494 MT PISGAH ROAD SW
SUPPLY, NC, 28462