N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16082-48-0942
State Number
22471

EQUIPMENT INSPECTED

State Number: **22471**
Capacity: 3000
Landings: 4
Volts: 208

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 06/15/2004
Complied: 06/15/2004

Floor to Floor: 1 to 4
Speed: 125
Rope Size: .
Entrances: 1

OWNER
CAM
P.O. BOX 8126
OCEAN ISLE BEACH, NC, 28469

OCCUPANT
ISLANDER RESORT - BLDG. #55
2 VIA DOLOROSA
OCEAN ISLE BEACH, NC, 28469

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
03/22/2016	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

2.2.2.4	Put the sump pump in proper working order.
8.6.4.7.4	Remove the water from the pit floor.
2.2.5.1	Put the pit lights in proper working order.
3.24.2.1	Add the correct amount of oil to the pumping unit reservoir.

Items must be corrected by: 05/22/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
CAM
P.O. BOX 8126
OCEAN ISLE BEACH, NC, 28469