N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16083-36-387
State Number
22766

EQUIPMENT INSPECTED

State Number: **22766**	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: OTIS	Speed: 100
Landings: 2	Installed: 02/07/2005	Rope Size:
Volts: 480	Complied: 02/07/2005	Entrances: 1

OWNER
S P M INVESTMENTS, LLC
2921 CROUSE LANE
BURLINGTON, NC, 27215

OCCUPANT
CAROLINA NUCLEAR MEDICINE
2921 CROUSE LANE
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
03/23/2016	Routine	Re-issued	36 - Kirkman	ALAMANCE

1

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 04/02/2016 Elevator Name: DR. MORAYATI

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: DR. MORAYATI 336-634-1400 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
S P M INVESTMENTS, LLC
2921 CROUSE LANE
BURLINGTON, NC, 27215