N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16090-36-5698
State Number
17863

EQUIPMENT INSPECTED

State Number: **17863**
Capacity: 4500
Landings: 4
Volts: 200

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 10/01/1998
Complied: 10/01/1998

Floor to Floor: B to 2
Speed: 110
Rope Size:
Entrances: 2

OWNER
DAVIS ST METHODIST CHURCH
606 E DAVIS ST
BURLINGTON, NC, 27215

OCCUPANT
DAVIS ST METHODIST CHURCH
606 E DAVIS ST
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
03/30/2016	Compliance	Issued	36 - Kirkman	ALAMANCE

1

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Alan Sasser,336-226-4457 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
DAVIS ST METHODIST CHURCH
606 E DAVIS ST
BURLINGTON, NC, 27215