



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**16097-65-0475**  
State Number  
**9472**

EQUIPMENT INSPECTED

State Number: <b>9472</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: ASHEVILLE	Speed: 100
Landings: 3	Installed: 05/16/1980	Rope Size:
Volts: 208	Complied: 05/16/1980	Entrances: 1

OWNER  
ALCO PROPERTY MANAGEMENT  
35 UNION  
MEMPHIS, TN, 38103

OCCUPANT  
ARROWHEAD APARTMENTS  
100 CHEERIO LANE  
ASHEVILLE, NC, 28803

INSPECTION INFORMATION

Inspection Date 04/06/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 65 - Kelley	County BUNCOMBE	11 B
-------------------------------	----------------------------	---------------------------------	--------------------------	--------------------	------

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 06/06/2016

Elevator Name: FRONT ELEVATOR / # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Kathy Allen 828-298-9390

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALCO PROPERTY MANAGEMENT  
35 UNION  
MEMPHIS, TN, 38103