N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16097-65-3283
State Number
9471

EQUIPMENT INSPECTED

State Number: **9471**
Capacity: 2500
Landings: 3
Volts: 208

Type of Unit: Passenger
Manuf: ASHEVILLE
Installed: 05/16/1980
Complied: 05/16/1980

Floor to Floor: 1 to 3
Speed: 100
Rope Size:
Entrances: 1

OWNER
ALCO PROPERTY MANAGEMENT
35 UNION - SUITE #200
MEMPHIS, TN, 38103

OCCUPANT
ARROWHEAD APARTMENTS
100 CHEERIO LANE
ASHEVILLE, NC, 28803

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County	
04/06/2016	Routine	Re-issued	65 - Kelley	BUNCOMBE	11 B

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order.

Items must be corrected by: 06/06/2016

Elevator Name: BACK ELEVATOR / # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Kathy Allen 828-298-9390

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
ALCO PROPERTY MANAGEMENT
35 UNION - SUITE #200
MEMPHIS, TN, 38103