



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**16099-48-2056**  
State Number  
**21610**

EQUIPMENT INSPECTED

State Number: <b>21610</b>	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 125
Landings: 4	Installed: 05/13/2003	Rope Size: 0
Volts: 208	Complied: 05/13/2003	Entrances: 1
OWNER	OCCUPANT	
CAM	ISLANDER RESORT - BLDG. #27	
P.O. BOX 8126	2 JAN STREET	
OCEAN ISLE BEACH, NC, 28469	OCEAN ISLE BEACH, NC, 28469	

INSPECTION INFORMATION

Inspection Date 04/08/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.1.1.2	Put the in car emergency telephone in proper working order.
2.27.3.1	Put the Phase I fire service feature in proper working order. [FIRE HAT AT KEY SW.]
2.27.3.1	Put the Phase I fire service feature in proper working order. [CAR ALARM LOW]

Items must be corrected by: 06/08/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: UNAVAILABLE

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

CAM  
P.O. BOX 8126  
OCEAN ISLE BEACH, NC, 28469