



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16103-48-326
State Number
26504

EQUIPMENT INSPECTED

State Number: 26504	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: TKE	Speed: 110
Landings: 2	Installed: 03/18/2009	Rope Size:
Volts: 208	Complied: 03/18/2009	Entrances: 1

OWNER

PARAGON BUILDING CORP
3811 PEACHTREE AVE STE 100
WILMINGTON, NC, 28403

OCCUPANT

OAK ISLAND FIRE DEPT
8510 E OAK ISLAND DRIVE
OAK ISLAND, NC, 28465

INSPECTION INFORMATION

Inspection Date 04/12/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.11.2.2.2 Perform the annual no load safety test

Items must be corrected by: 06/12/2016

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: C. ANSELMO

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

PARAGON BUILDING CORP
3811 PEACHTREE AVE STE 100
WILMINGTON, NC, 28403