



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16123-48-1598
State Number
27289

EQUIPMENT INSPECTED

State Number: 27289	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: TKE	Speed: 75
Landings: 2	Installed: 01/27/2010	Rope Size:
Volts: 208	Complied: 01/27/2010	Entrances: 1
OWNER	OCCUPANT	
TOWN OF SHALLOTTE	SHALLOTTE TOWN HALL	
106 CHEERS STREET	106 CHEERS STREET	
SHALLOTTE, NC, 28470	SHALLOTTE, NC, 28470	

INSPECTION INFORMATION

Inspection Date 05/02/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.3.3 Put the Phase II fire service feature in proper working order. [DR. REOPENING AFTER HALFWAY CLOSED WHEN DR CLOSE BUTTON HELD]
N/A CAR BUTTONS NOT STAYING LATCHED

Items must be corrected by: 07/02/2016

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: CHERYL

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

TOWN OF SHALLOTTE
106 CHEERS STREET
SHALLOTTE, NC, 28470