N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16125-48-1670
State Number
7058

EQUIPMENT INSPECTED

State Number: **7058**
Capacity: 4000
Landings: 5
Volts: 480

Type of Unit: Passenger
Manuf: THYSSEN KRUPP
Installed: 07/02/1974
Complied: 08/19/1992

Floor to Floor: 1 to 5
Speed: 100
Rope Size: 5/8
Entrances: 1

OWNER
DUKE ENERGY
8470 RIVER ROAD SE
SOUTHPORT, NC, 28461

OCCUPANT
DUKE ENERGY - REACTOR #1
8470 RIVER ROAD SE
SOUTHPORT, NC, 28461

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
05/04/2016	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

8.6.4.7.1 Clean the elevator pit.

Items must be corrected by: 07/04/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: MICHAEL ROSE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
DUKE ENERGY
8470 RIVER ROAD SE
SOUTHPORT, NC, 28461