



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16125-48-2418
State Number
7118

EQUIPMENT INSPECTED

State Number: 7118	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 10/24/1973	Rope Size: 1/2
Volts: 480	Complied: 12/10/1973	Entrances: 1
OWNER	OCCUPANT	
DUKE ENERGY	DUKE ENERGY - CONTROL ROOM	
8470 RIVER ROAD SE	8470 RIVER ROAD SE	
SOUTHPORT, NC, 28461	SOUTHPORT, NC, 28461	

INSPECTION INFORMATION

Inspection Date 05/04/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.7.1 Clean the elevator pit.
8.6.4.13.1[k] Properly maintain door closers, where required. [MOTOR ROOM DOOR TO CLOSE AND LOCK ON ITS OWN]

Items must be corrected by: 07/04/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: MICHAEL ROSE

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

DUKE ENERGY
8470 RIVER ROAD SE
SOUTHPORT, NC, 28461