



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**16137-48-2248**  
State Number  
**18812**

EQUIPMENT INSPECTED

|                            |                             |                        |
|----------------------------|-----------------------------|------------------------|
| State Number: <b>18812</b> | Type of Unit: Passenger     | Floor to Floor: 1 to 3 |
| Capacity: 2500             | Manuf: OTIS                 | Speed: 125             |
| Landings: 3                | Installed: 06/22/2000       | Rope Size:             |
| Volts: 208                 | Complied: 06/22/2000        | Entrances: 1           |
| OWNER                      | OCCUPANT                    |                        |
| C 3 INVESTMENTS OF NC      | HAMPTON INN                 |                        |
| 5181 SOUTHPORT/SUPPLY RD.  | 5181 SOUTH PORT / SUPPLY RD |                        |
| SOUTHPORT, NC, 28461       | SOUTH PORT, NC, 28461       |                        |

INSPECTION INFORMATION

|                               |                            |                                 |                          |                     |
|-------------------------------|----------------------------|---------------------------------|--------------------------|---------------------|
| Inspection Date<br>05/16/2016 | Type Inspection<br>Routine | Certificate Status<br>Re-issued | Inspector<br>48 - Martin | County<br>BRUNSWICK |
|-------------------------------|----------------------------|---------------------------------|--------------------------|---------------------|

10

VIOLATIONS

|            |   |
|------------|---|
| 2.27.1.1.2 | Put the in car emergency telephone in proper working order. |
| 2.26.12    | Provide Braille where needed. [1ST FL]                      |

Items must be corrected by: 07/16/2016

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: RICK

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

C 3 INVESTMENTS OF NC  
5181 SOUTHPORT/SUPPLY RD.  
SOUTHPORT, NC, 28461