



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16144-8-2599
State Number
18086

EQUIPMENT INSPECTED

State Number: 18086	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 95
Landings: 2	Installed: 12/16/1998	Rope Size:
Volts: 208	Complied: 12/17/1998	Entrances: 1

OWNER

SHRI JALARAM INC
2185 HANFORD RD
BURLINGTON, NC, 27215

OCCUPANT

MICROTEL HOTEL
2185 HANFORD RD
BURLINGTON, NC, 27215

INSPECTION INFORMATION

Inspection Date 05/23/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 8 - Burris	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

1

VIOLATIONS

8.6.4.7	REMOVE MATERIAL STORED IN MACHINE ROOM. (NO STORAGE)
8.6.4.19	AJUST BOTTOM NORMAL LIMIT

Items must be corrected by: 07/23/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: BHAVNA PATEL

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

SHRI JALARAM INC
2185 HANFORD RD
BURLINGTON, NC, 27215