



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16154-16-1820
State Number
29292

EQUIPMENT INSPECTED

State Number: 29292	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: SCHINDLER	Speed: 100
Landings: 2	Installed: 04/15/2014	Rope Size:
Volts: 208	Complied: 04/15/2014	Entrances: 1
OWNER	OCCUPANT	
WASHEYE LLC	WASHINGTON EYE CENTER	
4005 RIVER PARK DRIVE	1730 CAROLINA AVENUE	
SUFFOLK, VA, 23435	WASHINGTON, NC, 27889	

INSPECTION INFORMATION

Inspection Date 06/02/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 16 - Moore	County BEAUFORT
-------------------------------	----------------------------	---------------------------------	-------------------------	--------------------

7

VIOLATIONS

2.14.7.1.4 Put the car top light in working order.

Items must be corrected by: 08/01/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Connie / Front Desk

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WASHEYE LLC
4005 RIVER PARK DRIVE
SUFFOLK, VA, 23435