



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**16159-48-4640**  
State Number  
**26864**

EQUIPMENT INSPECTED

State Number: <b>26864</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2000	Manuf: TKE	Speed: 55
Landings: 3	Installed: 07/21/2009	Rope Size:
Volts: 230	Complied: 07/21/2009	Entrances: 1
OWNER	OCCUPANT	
INLET VIEW BAR & GRILL	INLET VIEW BAR & GRILL	
1800 VILLAGE POINT RD	1800 VILLAGE POINT ROAD	
SHALLOTTE, NC, 28470	SHALLOTTE, NC, 28470	

INSPECTION INFORMATION

Inspection Date 06/07/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

2.27.1.1.2	Put the in car emergency telephone in proper working order.
N/A	REPAIR DOOR NUDGING TO OPERATE

Items must be corrected by: 08/07/2016

Elevator Name: #1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: SAMANTHA

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

INLET VIEW BAR & GRILL  
1800 VILLAGE POINT RD  
SHALLOTTE, NC, 28470