



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16165-36-1558
State Number
1037

EQUIPMENT INSPECTED

State Number: 1037	Type of Unit: Freight	Floor to Floor: B to 1
Capacity: 3000	Manuf: WESTBROOK	Speed: 60
Landings: 2	Installed: 02/17/1948	Rope Size: 1/2
Volts: 220	Complied: 04/04/1991	Entrances: 2
OWNER	OCCUPANT	
GRAHAM DYEING & FINISHING	GRAHAM DYEING & FINISHING	
110 N BROAD ST	110 N BROAD ST	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 06/13/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: GWEN DUGGINS 336-228-9981

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

GRAHAM DYEING & FINISHING
110 N BROAD ST
BURLINGTON, NC, 27215