N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16165-36-2371
State Number
24204

EQUIPMENT INSPECTED

State Number: **24204**	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2000	Manuf: THYSSEN KRUPP	Speed: 110
Landings: 2	Installed: 11/01/2006	Rope Size: 0
Volts: 208	Complied:	Entrances: 1

OWNER
MACINTOSH ON THE LAKE
4210 BONNAR BRIDGE
BURLINGTON, NC, 27244

OCCUPANT
CLUB HOUSE "LOCH RIDGE MANOR"
4210 BONNAR BRIDGE
BURLINGTON, NC, 27244

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
06/13/2016	Routine	Re-issued	36 - Kirkman	ALAMANCE

1

VIOLATIONS

Elevator Name: LOCH RIDGE MANOR

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: Jeniffer port 919.848.4911 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to: MACINTOSH ON THE LAKE
4210 BONNAR BRIDGE
BURLINGTON, NC, 27244