



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16165-48-2581
State Number
17403

EQUIPMENT INSPECTED

State Number: 17403	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: US ELEVATOR	Speed: 125
Landings: 2	Installed: 07/10/1998	Rope Size:
Volts: 460	Complied: 07/16/1998	Entrances: 1
OWNER	OCCUPANT	
BRUNSWICK COMM COLLEGE	BRUNSWICK COMMUNITY COLLEGE	
PO BOX 30	50 COLLEGE RD.	
SUPPLY, NC, 28462	SUPPLY, NC, 28462	

INSPECTION INFORMATION

Inspection Date 06/13/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: TOM

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BRUNSWICK COMM COLLEGE
PO BOX 30
SUPPLY, NC, 28462