



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16165-48-5089
State Number
12433

EQUIPMENT INSPECTED

State Number: 12433	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 2	Installed: 01/20/1988	Rope Size:
Volts: 480	Complied: 01/26/1988	Entrances: 1
OWNER	OCCUPANT	
BRUNSWICK COMMUNITY COLLEGE	BRUNSWICK COMM COLLEGE	
PO BOX 30	50 COLLEGE RD.	
SUPPLY, NC, 28462	SUPPLY, NC, 28462	

INSPECTION INFORMATION

Inspection Date 06/13/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.8.9	Signs. Caution signs shall be provided. Damaged or missing signs shall be replaced. [2ND. FL.]
8.11.2.2.2	Perform the annual no load safety test

Items must be corrected by: 08/13/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: TOM

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BRUNSWICK COMMUNITY COLLEGE
PO BOX 30
SUPPLY, NC, 28462