



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**16168-36-3383**  
State Number  
**30196**

EQUIPMENT INSPECTED

State Number: <b>30196</b>	Type of Unit: Passenger	Floor to Floor: 1 to 4
Capacity: 3500	Manuf: TKE	Speed: 150
Landings: 4	Installed: 05/16/2016	Rope Size:
Volts: 208	Complied: 05/16/2016	Entrances: 1
OWNER	OCCUPANT	
ELON UNIVERSITY	PARK PLACE AT ELON	
101 CAMPUS RIVE	202 W HAGGARD AVENUE	
ELON, NC, 27244	ELON, NC, 27244	

INSPECTION INFORMATION

Inspection Date 06/16/2016	Type Inspection New	Certificate Status Not Issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	------------------------	----------------------------------	---------------------------	--------------------

1

VIOLATIONS

2.27 Place fire alarm in proper working order

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Office

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ELON UNIVERSITY  
101 CAMPUS RIVE  
ELON, NC, 27244