N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16174-48-1814
State Number
24906

EQUIPMENT INSPECTED

State Number: **24906**
Capacity: 3500
Landings: 6
Volts: 208

Type of Unit: Passenger
Manuf: OTIS
Installed: 06/25/2007
Complied:

Floor to Floor: 1 to 6
Speed: 150
Rope Size:
Entrances: 1

OWNER
SEASIDELANDING PARTNERS LLC
7265 SEASHELL LANE SW
OCEAN ISLE BEACH, NC, 28469

OCCUPANT
SEASIDE LANDING CONDOS
7265 SEASHELL LANE SW
OCEAN ISLE BEACH, NC, 28469

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
06/22/2016	Routine	Re-issued	48 - Martin	BRUNSWICK

10

VIOLATIONS

8.6.4.8.2 Remove all materials from machine room (machinery space) not pertaining to the maintenance or operation of the elevator(s).

Items must be corrected by: 08/22/2016

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: UNAVAILABLE

Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
SEASIDELANDING PARTNERS LLC
7265 SEASHELL LANE SW
OCEAN ISLE BEACH, NC, 28469