N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16179-36-3378
State Number
6947

EQUIPMENT INSPECTED

State Number: **6947**
Capacity: 3000
Landings: 2
Volts: 220

Type of Unit: Freight
Manuf: SOUTHERN
Installed: 03/15/1971
Complied: 03/15/1971

Floor to Floor: B to 1
Speed: 65
Rope Size:
Entrances: 1

OWNER
SIMS POTTERY
563 W MOORE ST
GRAHAM, NC, 27253

OCCUPANT
SIMS POTTERY
563 W MOORE ST
GRAHAM, NC, 27253

INSPECTION INFORMATION

Inspection Date	Type Inspection	Certificate Status	Inspector	County
06/27/2016	Routine	Re-issued	36 - Kirkman	ALAMANCE

1

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into complainace with current codes.

Violations pointed out to: DOUG SEARS 336-228-1518 Inspector _____

THIS IS NOT AN INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:
SIMS POTTERY
563 W MOORE ST
GRAHAM, NC, 27253