



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16181-36-2968
State Number
12820

EQUIPMENT INSPECTED

State Number: 12820	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: OTIS	Speed: 125
Landings: 3	Installed: 12/20/1988	Rope Size:
Volts: 208	Complied: 12/20/1988	Entrances: 1

OWNER

ALAMANCE COMMUNITY COLLEGE
1247 JIMMIE-KERR RD
GRAHAM, NC, 27253

OCCUPANT

ALAMANCE COMMUNITY COLLEGE
1247 JIMMIE-KERR ROAD
GRAHAM, NC, 27253

INSPECTION INFORMATION

Inspection Date 06/29/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Eric (336) 578-2002

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE COMMUNITY COLLEGE
1247 JIMMIE-KERR RD
GRAHAM, NC, 27253