



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16187-36-0733
State Number
22572

EQUIPMENT INSPECTED

State Number: 22572	Type of Unit: Passenger	Floor to Floor: 1 to 9
Capacity: 2500	Manuf: OTIS	Speed: 200
Landings: 9	Installed: 04/26/2005	Rope Size: .
Volts: 208	Complied: 09/14/2005	Entrances: 1
OWNER 21 BATTERY PARK L.L.C. C/O IPM CORP./ ATTN:STEPHANIE CLARK ARDEN, NC, 28704-0580		OCCUPANT 21 BATTERY PARK CONDOMINIUM 21 BATTERY PARK ASHEVILLE, NC, 28801

INSPECTION INFORMATION

Inspection Date 07/05/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County BUNCOMBE	11 A
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------	------

VIOLATIONS

Elevator Name: ELEVATOR # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Stephanie Clark

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

21 BATTERY PARK L.L.C.
C/O IPM CORP./ ATTN:STEPHANIE CLARK
ARDEN, NC, 28704-0580