



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16188-48-4598
State Number
30426

EQUIPMENT INSPECTED

State Number: 30426	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: SCHINDLER	Speed: 150
Landings: 2	Installed: 06/21/2016	Rope Size:
Volts: 480	Complied:	Entrances: 1
OWNER	OCCUPANT	
BRUNSWICK COUNTY OPERATIONS	NORTH BRUNSWICK HIGH SCHOOL	
30 GOVERNMENT CENTER DRIVE	1395 SCORPION DRIVE NE	
BOLIVIA, NC, 28422	LELAND, NC, 28451	

INSPECTION INFORMATION

Inspection Date 07/06/2016	Type Inspection New	Certificate Status Not Issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	------------------------	----------------------------------	--------------------------	---------------------

10

VIOLATIONS

N/A UNIT FAILED DUE TO FIRE RECALL ISSUES

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JOSEPH & JIM

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BRUNSWICK COUNTY OPERATIONS
30 GOVERNMENT CENTER DRIVE
BOLIVIA, NC, 28422