



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16189-48-3512
State Number
28994

EQUIPMENT INSPECTED

State Number: 28994	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 4500	Manuf: TKE	Speed: 125
Landings: 2	Installed: 01/27/2014	Rope Size:
Volts: 460	Complied:	Entrances: 1
OWNER	OCCUPANT	
TOWN OF LELAND	TOWN OF LELAND NEW TOWN HALL & POLICE HQ	
102 TOWN HALL DRIVE	102 TOWN HALL DRIVE	
LELAND, NC, 28451	LELAND, NC, 28451	

INSPECTION INFORMATION

Inspection Date 07/07/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

8.6.4.8.2 Remove all materials from machine room (machinery space) not pertaining to the maintenance or operation of the elevator(s).

Items must be corrected by: 09/07/2016

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: NEIL

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

TOWN OF LELAND
102 TOWN HALL DRIVE
LELAND, NC, 28451