



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16189-65-2161
State Number
H2510

EQUIPMENT INSPECTED

State Number: H2510	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: GARAVENTA	Speed: 30
Landings: 2	Installed: 12/19/2013	Rope Size: 3/8
Volts: 230	Complied: 12/19/2013	Entrances: 2
OWNER BANNER ELK VISTA PROPERTIES PO BOX 2074 BANNER ELK, NC, 28604	OCCUPANT VISTAS @ BANNER ELK #6 410 PENNY LANE BANNER ELK, NC, 28604	

INSPECTION INFORMATION

Inspection Date 07/07/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 65 - Kelley	County AVERY
-------------------------------	----------------------------	---------------------------------	--------------------------	-----------------

6

VIOLATIONS

- 8.6.4.8.2 Articles or materials not necessary for the maintenance or operation of the elevator shall not be stored in machine rooms and machinery spaces.
- 8.6.10.2 Provide proper access keys for access, operation, inspection, maintenance, repair and emergency available to elevator personnel, to be kept on the premises and not accessible to the general public (see 8.1)
- 8.11.1.6 Provide the appropriate test tag.
- 8.11.3.2.1 Perform the annual relief valve test

Items must be corrected by: 09/07/2016

Elevator Name: # 6

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JP 828-964-2458

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BANNER ELK VISTA PROPERTIES
PO BOX 2074
BANNER ELK, NC, 28604