



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16189-65-3050
State Number
H2442

EQUIPMENT INSPECTED

State Number: H2442	Type of Unit: Hand Lift	Floor to Floor: 1 to 2
Capacity: 750	Manuf: GARAVENTA	Speed: 30
Landings: 2	Installed: 02/21/2013	Rope Size:
Volts: 230	Complied:	Entrances: 2
OWNER	OCCUPANT	
BANNER ELK VISTA PROPERTIES LLC	THE VISTAS	
PO BOX 2074	325 PENNY LANE	
BANNER ELK, NC, 28604	BANNER ELK, NC, 28604	

INSPECTION INFORMATION

Inspection Date 07/07/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 65 - Kelley	County AVERY
-------------------------------	----------------------------	---------------------------------	--------------------------	-----------------

6

VIOLATIONS

- 2.27.1.1.2 Put the in car emergency telephone in proper working order.
- 8.6.10.2 Provide proper access keys for access, operation, inspection, maintenance, repair and emergency available to elevator personnel, to be kept on the premises and not accessible to the general public (see 8.1)
- 8.11.1.6 Provide the appropriate test tag.
- 8.11.3.2.1 Perform the annual relief valve test
- 2.7.5.1 Put the machine room lights in working order.

Items must be corrected by: 09/07/2016

Elevator Name: 3

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JP 828-964-2458

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BANNER ELK VISTA PROPERTIES LLC
PO BOX 2074
BANNER ELK, NC, 28604