



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16189-65-4566
State Number
H2353

EQUIPMENT INSPECTED

| | | |
|-----------------------------|-------------------------|------------------------|
| State Number: H2353 | Type of Unit: Hand Lift | Floor to Floor: 1 to 2 |
| Capacity: 750 | Manuf: GARAVENTA | Speed: 30 |
| Landings: 2 | Installed: 04/17/2012 | Rope Size: |
| Volts: 230 | Complied: | Entrances: 2 |
| OWNER | OCCUPANT | |
| BANNER ELK VISTA PROPERTIES | THE VISTAS | |
| PO BOX 2074 | 317 PENNY LANE | |
| BANNER ELK, NC, 28604 | BANNER ELK, NC, 28604 | |

INSPECTION INFORMATION

| | | | | |
|-------------------------------|----------------------------|---------------------------------|--------------------------|-----------------|
| Inspection Date 07/07/2016 | Type Inspection Routine | Certificate Status Re-issued | Inspector 65 - Kelley | County AVERY |
|-------------------------------|----------------------------|---------------------------------|--------------------------|-----------------|

6

VIOLATIONS

- 8.6.10.2 Provide proper access keys for access, operation, inspection, maintenance, repair and emergency available to elevator personnel, to be kept on the premises and not accessible to the general public (see 8.1)
- 8.11.1.6 Provide the appropriate test tag.
- 8.11.3.2.1 Perform the annual relief valve test

Items must be corrected by: 09/07/2016

Elevator Name: # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: JP 828-964-2458

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

BANNER ELK VISTA PROPERTIES
PO BOX 2074
BANNER ELK, NC, 28604