



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16193-65-0433
State Number
16223

EQUIPMENT INSPECTED

State Number: 16223	Type of Unit: Passenger	Floor to Floor: LL to UL
Capacity: 2500	Manuf: SCHINDLER	Speed: 125
Landings: 3	Installed: 11/14/1996	Rope Size: 0
Volts: 460	Complied: 11/25/1996	Entrances: 1
OWNER	OCCUPANT	
AVERY COUNTY SCHOOLS	FREEDOM TRAIL ELEMENTARY	
775 CRANBERRY STREET	6230 HWY19 EAST	
NEWLAND, NC, 28657	NEWLAND, NC, 28657	

INSPECTION INFORMATION

Inspection Date 07/11/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 65 - Kelley	County AVERY
-------------------------------	----------------------------	---------------------------------	--------------------------	-----------------

6

VIOLATIONS

8.6.4.7.1	Clean the elevator pit.
2.14.7.1.3	Put the in car emergency light in working order.
2.7.2.1	Elevator equipment only to be located in the machine room.

Items must be corrected by: 09/11/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Darryl 828387-1564

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

AVERY COUNTY SCHOOLS
775 CRANBERRY STREET
NEWLAND, NC, 28657