



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**16194-48-3355**  
State Number  
**25981**

EQUIPMENT INSPECTED

State Number: <b>25981</b>	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2500	Manuf: TKE	Speed: 130
Landings: 2	Installed: 01/27/2009	Rope Size:
Volts: 200	Complied: 01/27/2009	Entrances: 1

OWNER

DIXIE GENERAL CONTRACTORS  
1236 N TEACHY ROAD  
WALLACE, NC, 28466

OCCUPANT

HOLDEN BEACH NEW TOWN HALL  
110 ROTHSCHILD STREET  
HOLDEN BEACH, NC, 28462

INSPECTION INFORMATION

Inspection Date 07/12/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	---------------------------------	--------------------------	---------------------

10

VIOLATIONS

Elevator Name: # 1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: DAVID

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

DIXIE GENERAL CONTRACTORS  
1236 N TEACHY ROAD  
WALLACE, NC, 28466