



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16194-48-5922
State Number
27852

EQUIPMENT INSPECTED

State Number: 27852	Type of Unit: Passenger	Floor to Floor: 1 to 2
Capacity: 2100	Manuf: SCHINDLER	Speed: 40
Landings: 2	Installed: 05/10/2011	Rope Size:
Volts: 230	Complied:	Entrances: 1
OWNER	OCCUPANT	
WATERBORO VILLAGE MGMT	WATERWAY COVE CLUBHOUSE	
1140 308 KILDAIRE FARM ROAD	100 WATERWAY DRIVE SW	
CARY, NC, 27512	OCEAN ISLE, NC, 28469	

INSPECTION INFORMATION

Inspection Date 07/12/2016	Type Inspection Removed	Certificate Status Not Issued	Inspector 48 - Martin	County BRUNSWICK
-------------------------------	----------------------------	----------------------------------	--------------------------	---------------------

10

VIOLATIONS

n/a	PARTIAL INSPECTION - UNIT NOT RUNNING [3RD YR] - REMOVED FROM SERVICE
8.11.2.3	Perform a 5 year full load safety test

Elevator Name: #1

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: RYAN

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

WATERBORO VILLAGE MGMT
1140 308 KILDAIRE FARM ROAD
CARY, NC, 27512