



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16196-65-0747
State Number
11260

EQUIPMENT INSPECTED

| | | |
|----------------------------|--------------------------|------------------------|
| State Number: 11260 | Type of Unit: Freight | Floor to Floor: 2 to 3 |
| Capacity: 1500 | Manuf: ACE | Speed: 100 |
| Landings: 2 | Installed: 07/15/1986 | Rope Size: 0 |
| Volts: 208 | Complied: 07/18/1986 | Entrances: 1 |
| OWNER | OCCUPANT | |
| N.C. WILDERNESS LIMITED | LINVILLE RIDGE CLUBHOUSE | |
| P.O. BOX 704 | 7000 RIDGE ROAD | |
| LINVILLE, NC, 28646 | LINVILLE, NC, 28646 | |

INSPECTION INFORMATION

| | | | | |
|-------------------------------|----------------------------|---------------------------------|--------------------------|-----------------|
| Inspection Date 07/14/2016 | Type Inspection Routine | Certificate Status Re-issued | Inspector 65 - Kelley | County AVERY |
|-------------------------------|----------------------------|---------------------------------|--------------------------|-----------------|

6

VIOLATIONS

| | |
|------------|---|
| 2.14.7.1.4 | Put the car top light in working order. |
| 2.7.2.2.1 | Provide clear access to the machine room. |

Items must be corrected by: 09/14/2016

Elevator Name: # 2

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Michael Sparks 828-387-6979

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

N.C. WILDERNESS LIMITED
P.O. BOX 704
LINVILLE, NC, 28646