



N C Department of Labor Elevator Bureau  
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in  
any correspondence relating to your equipment  
[www.nclabor.com/elevator.htm](http://www.nclabor.com/elevator.htm)  
919-707-7927

Report Number  
**16196-65-2249**  
State Number  
**26961**

EQUIPMENT INSPECTED

State Number: <b>26961</b>	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: TKE	Speed: 150
Landings: 3	Installed: 04/01/2010	Rope Size: 0
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
GRANDFATHER MOUNTAIN	GRANDFATHER MOUNTAIN TOP SHOP	
P.O. BOX 129	2050 BLOWING ROCK HWY	
LINVILLE, NC, 28646	LINVILLE, NC, 28646	

INSPECTION INFORMATION

Inspection Date 07/14/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 65 - Kelley	County AVERY
-------------------------------	----------------------------	---------------------------------	--------------------------	-----------------

6

VIOLATIONS

2.27.1.1.2 Put the in car emergency telephone in proper working order. 3rd notice. Phone must be repaired within ten days.

Items must be corrected by: 07/24/2016

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: Grandfather Mountain Top Shop 828-733-2800

Inspector \_\_\_\_\_

THIS IS NOT AN  
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

GRANDFATHER MOUNTAIN  
P.O. BOX 129  
LINVILLE, NC, 28646