



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16200-36-3816
State Number
22750

EQUIPMENT INSPECTED

State Number: 22750	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2100	Manuf: THYSSEN KRUPP	Speed: 100
Landings: 3	Installed: 04/07/2005	Rope Size:
Volts: 208	Complied: 04/07/2005	Entrances: 1
OWNER	OCCUPANT	
ALAMANCE COUNTRY CLUB	ALAMANCE COUNTRY CLUB	
2402 PINEWAY DRIVE	2402 PINEWAY DRIVE	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 07/18/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: MATT SOMMER 336-584-9848

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ALAMANCE COUNTRY CLUB
2402 PINEWAY DRIVE
BURLINGTON, NC, 27215