



N C Department of Labor Elevator Bureau
1101 Mail Service Center, Raleigh, NC 27699-1101

INSPECTION REPORT

IMPORTANT: Always use State Number in
any correspondence relating to your equipment
www.nclabor.com/elevator.htm
919-707-7927

Report Number
16211-36-5542
State Number
25399

EQUIPMENT INSPECTED

State Number: 25399	Type of Unit: Passenger	Floor to Floor: 1 to 3
Capacity: 2500	Manuf: SCANDO	Speed: 100
Landings: 3	Installed: 10/26/2007	Rope Size:
Volts: 208	Complied:	Entrances: 1
OWNER	OCCUPANT	
ETHAN POINTE APARTMENTS	ETHAN POINTE AOARTMENTS	
2978 ETHAN POINTE DRIVE	1176 KIRKPATRICK ROAD	
BURLINGTON, NC, 27215	BURLINGTON, NC, 27215	

INSPECTION INFORMATION

Inspection Date 07/29/2016	Type Inspection Routine	Certificate Status Re-issued	Inspector 36 - Kirkman	County ALAMANCE
-------------------------------	----------------------------	---------------------------------	---------------------------	--------------------

1

VIOLATIONS

Notify the Elevator Bureau in writing on Corrected Violations Form when the following corrections have been made in order to bring your equipment into compliance with current codes.

Violations pointed out to: KAREN VEZINA 336-584-3337

Inspector _____

THIS IS NOT AN
INVOICE

To make changes to the invoice mailing address please call: 919-733-0372

An invoice will be mailed to:

ETHAN POINTE APARTMENTS
2978 ETHAN POINTE DRIVE
BURLINGTON, NC, 27215